



## Settings

<b>Range</b>	Multi9	
<b>Circuit-breaker</b>	DPN.N Vigi	
<b>Trip unit/curve</b>	C	
<b>Rating</b>	6.00	
<b>Long-time</b>		
<b>lo</b>		
<b>lr</b>		
<b>tr</b>		
<b>Short-time</b>		
<b>Im/l<sub>sd</sub></b>		
<b>I<sup>2</sup>t (delay)</b>		
<b>t<sub>m</sub>/t<sub>sd</sub></b>		
<b>Instantaneous</b>		
<b>li</b>	45.0A	
<b>Discrimination</b>		
<b>Limit</b>	Upstream device	